

**ELECTRICITY INDUSTRY PARTICIPATION CODE  
DISTRIBUTED UNMETERED LOAD AUDIT REPORT**

**VERITEK**

For

**INVERCARGILL CITY COUNCIL AND  
MERIDIAN ENERGY LIMITED**

**NZBN: 9429037696863**

Prepared by: Rebecca Elliot

Date audit commenced: 7 February 2024

Date audit report completed: 19 April 2024

Audit report due date: 12-May-24

---

## TABLE OF CONTENTS

Executive summary .....	3
Audit summary .....	4
Non-compliances.....	4
Recommendations .....	6
Issues 6	
1. Administrative.....	7
1.1. Exemptions from Obligations to Comply with Code.....	7
1.2. Structure of Organisation.....	7
1.3. Persons involved in this audit .....	8
1.4. Hardware and Software .....	8
1.5. Breaches or Breach Allegations .....	8
1.6. ICP Data.....	9
1.7. Authorisation Received .....	9
1.8. Scope of Audit .....	9
1.9. Summary of previous audit.....	10
1.10. Distributed unmetered load audits (Clause 16A.26 and 17.295F).....	11
2. DUML database requirements.....	13
2.1. Deriving submission information (Clause 11(1) of Schedule 15.3).....	13
2.2. ICP identifier and items of load (Clause 11(2)(a) and (aa) of Schedule 15.3) .....	15
2.3. Location of each item of load (Clause 11(2)(b) of Schedule 15.3).....	15
2.4. Description and capacity of load (Clause 11(2)(c) and (d) of Schedule 15.3) .....	15
2.5. All load recorded in database (Clause 11(2A) of Schedule 15.3).....	16
2.6. Tracking of load changes (Clause 11(3) of Schedule 15.3).....	17
2.7. Audit trail (Clause 11(4) of Schedule 15.3) .....	18
3. Accuracy of DUML database .....	19
3.1. Database accuracy (Clause 15.2 and 15.37B(b)).....	19
3.2. Volume information accuracy (Clause 15.2 and 15.37B(c)).....	22
Conclusion .....	25
Participant response.....	26

## EXECUTIVE SUMMARY

This audit of the **Invercargill City Council (ICC)** Unmetered Streetlights DUML database and processes was conducted at the request of **Meridian NZ Limited (Meridian)** in accordance with clause 15.37B. The purpose of this audit is to verify that the volume information is being calculated accurately, and that profiles have been correctly applied.

The audit was conducted in accordance with the audit guidelines for DUML audits version 1.1.

Meridian reconciles this DUML load using the DST profile.

The on and off times are derived from a data logger read by AMS and are used to create a shape file. Meridian supplies AMS with the capacity information and AMS calculates the kWh figure for each ICP and includes this in the relevant AV080 file. This process was audited during Meridian's reconciliation participant audit and the AMS agent audit. Compliance was confirmed for both parties.

The error in submission identified in the last audit has been corrected and I confirmed that volumes submitted matched the report for February 2024.

The field audit found that the database was not within the allowable +/-5% accuracy threshold. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates. This is a similar result to the last audit. Most of the discrepancies relate to errors made during the LED upgrade programme of work that finished some years ago. ICC intend to undertake their own field audit programme to correct these historic errors.

The audit found four non-compliances and makes no recommendations. The future risk rating of 20 indicates that the next audit be completed in three months. I have considered this in conjunction with Meridian's responses, and the update received from ICC confirming corrections have been made where possible and recommend that the next audit be nine months.

The matters raised are detailed below:

## AUDIT SUMMARY

### NON-COMPLIANCES

Subject	Section	Clause	Non-Compliance	Controls	Audit Risk Rating	Breach Risk Rating	Remedial Action
Deriving submission information	2.1	11(1) of Schedule 15.3	<p>Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates as recorded in <b>section 3.1</b>.</p> <p>Festive light volume not submitted for the period electrically connected from 6/12/2024-17/01/2024.</p> <p>23 of 38 discrepancies from the previous audit not corrected.</p> <p>Submission is based on a snapshot and does not consider the dates of changes during the month.</p>	Moderate	High	6	Identified
All load recorded in database	2.5	11(2A) of Schedule 15.3	<p>Eight additional lights were found in the field of the 322 items of load sampled.</p>	Moderate	Low	2	Identified

Subject	Section	Clause	Non-Compliance	Controls	Audit Risk Rating	Breach Risk Rating	Remedial Action
Database accuracy	3.1	15.2 and 15.37B(b)	Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates.  Incorrect ballast applied for one lamp.  23 of 38 discrepancies from the previous audit not corrected.	Moderate	High	6	Identified
Volume information accuracy	3.2	15.2 and 15.37B(c)	Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates as recorded in <b>section 3.1</b> .  Festive light volume not submitted for the period electrically connected from 6/12/2024-17/01/2024.  23 of 38 discrepancies from the previous audit not corrected.  Submission is based on a snapshot and does not consider the dates of changes during the month.	Moderate	High	6	Identified
Future Risk Rating						20	

<b>Future risk rating</b>	0	1-4	5-8	9-15	16-18	19+
<b>Indicative audit frequency</b>	36 months	24 months	18 months	12 months	6 months	3 months

## RECOMMENDATIONS

Subject	Section	Description	Action
		Nil	

## ISSUES

Subject	Section	Description	Issue
		Nil	

## 1. ADMINISTRATIVE

### 1.1. Exemptions from Obligations to Comply with Code

#### Code reference

Section 11 of Electricity Industry Act 2010.

#### Code related audit information

Section 11 of the Electricity Industry Act provides for the Electricity Authority to exempt any participant from compliance with all or any of the clauses.

#### Audit observation


Section 11 of the Electricity Industry Act provides for the Electricity Authority to exempt any participant from compliance with all or any of the clauses.

#### Audit commentary

There are no exemptions in place relevant to the scope of this audit.

### 1.2. Structure of Organisation

Meridian provided a copy of their organisational structure:



### 1.3. Persons involved in this audit

Auditor:

Name	Title	Company
Rebecca Elliot	Auditor	Veritek

Other personnel assisting in this audit were:

Name	Title	Company
Melanie Mathews	Quality and Compliance Advisor	Meridian Energy
Gama Rajapaksa	Asset Engineer - Transport	Invercargill CC
Russell Pearson	Chief Engineer	Invercargill CC

### 1.4. Hardware and Software

The SQL database used for the management of DUML is remotely hosted by thinkproject New Zealand Limited. The database is commonly known as "RAMM" which stands for "Road Assessment and Maintenance Management". The specific data used for DUML is held in the Streetlight tables. thinkproject New Zealand Limited backs up the database and assists with disaster recovery as part of their hosting service.

Pocket RAMM is used in the field by Network Electrical Servicing.

Access to the database is secure by way of password protection.

Systems used by the trader, and their agent, to calculate submissions are assessed as part of the reconciliation participant audit and agent audits.

### 1.5. Breaches or Breach Allegations

There are no breach allegations relevant to the scope of this audit.



## 1.6. ICP Data

ICP Number	Description	NSP	Number of items of load	Database wattage (watts)
0008801003TPFE8	ICC LIGHTS – TPC URBAN	INV0331	1,300	55,589
0008801013TP545	ICC LIGHTS - TPC RURAL	INV0331	102	8,464
0008801050TPB20	ICC HIGHWAY LIGHTS - TPC URBAN	INV0331	177	41,387
0008801051TP765	ICC HIGHWAY LIGHTS - TPC RURAL	INV0331	88	15,350
0008803002NV4BD	ICC LIGHTS - EIL INVERCARGILL	INV0331	4,641	248,879
0008803012NVE10	ICC LIGHTS - EIL INVERCARGILL	INV0331	434	16,685
0008803013NV255	ICC HIGHWAY LIGHTS EIL BLUFF	INV0331	70	11,,443
0088030031NVB6F	ICC HIGHWAY LIGHTS EIL INVERCARGILL	INV0331	421	113,843
<b>Total</b>			<b>7,233</b>	<b>500,197</b>

## 1.7. Authorisation Received

All information was provided directly by Meridian and ICC.

## 1.8. Scope of Audit


This audit of the ICC DUMML database and processes was conducted at the request of Meridian, in accordance with clause 15.37B. The purpose of this audit is to verify that the volume information is being calculated accurately, and that profiles have been correctly applied.

The audit was conducted in accordance with the audit guidelines for DUMML audits version 1.1.

Meridian use ICC's RAMM database for submission. Infrastructure Alliance provide a monthly report to Meridian of this database on behalf of ICC.

New connection, fault, and maintenance work is completed by Network Electrical Servicing. Pocket RAMM is used in the field to issue work and record changes in the field into RAMM.

The scope of the audit encompasses the collection, security and accuracy of the data, including the preparation of submission information based on the database reporting. The diagram below shows the audit boundary for clarity.



The field audit was undertaken of a statistical sample of 322 items of load on 6<sup>th</sup> April 2024.

### 1.9. Summary of previous audit

The previous audit was undertaken by Steve Woods of Veritek Limited in June 2023. Four non-compliances were identified, and two recommendations were made. The status of the non-compliances and recommendation are described below.

### Table of Non-Compliance

Subject	Section	Clause	Non-Compliance	Status
Deriving submission information	2.1	11(1) of Schedule 15.3	<p>Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 121,500 kWh lower than the DUML database indicates as recorded in <b>section 3.1</b>.</p> <p>Incorrect ballast applied for 15 lamps resulting in an estimated over submission of 4,280 kWh per annum.</p> <p>kW figures used for submission differ from those in the spreadsheet, resulting in over submission of approx. 70,000 kWh between March and May 2023.</p> <p>Submission is based on a snapshot and does not consider the dates of changes during the month.</p>	<p>Still existing</p> <p>Still existing for one lamp</p> <p>Cleared</p> <p>Still existing</p>
All load recorded in database	2.5	11(2A) of Schedule 15.3	12 additional lights were found in the field of the 397 items of load sampled.	Still existing

Subject	Section	Clause	Non-Compliance	Status
Database accuracy	3.1	15.2 and 15.37B(b)	Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 121,500 kWh lower than the DUML database indicates.  Incorrect ballast applied for 15 lamps resulting in an estimated over submission of 4,280 kWh per annum.  11 of 16 discrepancies from the previous audit not corrected.	Still existing  Still existing for one lamp  Still existing
Volume information accuracy	3.2	15.2 and 15.37B(c)	Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 121,500 kWh lower than the DUML database indicates as recorded in <b>section 3.1</b> .  Incorrect ballast applied for 15 lamps resulting in an estimated over submission of 4,280 kWh per annum.  kW figures used for submission differ from those in the spreadsheet, resulting in over submission of approx. 70,000 kWh between March and May 2023.  Submission is based on a snapshot and does not consider the dates of changes during the month.	Still existing  Still existing for one lamp  Cleared  Still existing

## Table of Recommendations

Subject	Section	Non-Compliance	Status
GPS coordinates	2.3	Populate the GPS coordinates for the 278 items of load where this field is blank.	Adopted
Database updates	3.1	Investigate the discrepancies recorded to identify why some updates are not being updated in the database.	Not repeated

### 1.10. Distributed unmetered load audits (Clause 16A.26 and 17.295F)

#### Code reference

Clause 16A.26 and 17.295F

#### Code related audit information

Retailers must ensure that DUML database audits are completed:

1. by 1 June 2018 (for DUML that existed prior to 1 June 2017),
2. within three months of submission to the reconciliation manager (for new DUML),
3. within the timeframe specified by the Authority for DUML that has been audited since 1 June 2017.

#### Audit observation

Meridian have requested Veritek to undertake this streetlight audit.

**Audit commentary**

This audit report confirms that the requirement to conduct an audit has been met for this database within the required timeframe.

**Audit outcome**

Compliant

## 2. DUML DATABASE REQUIREMENTS

### 2.1. Deriving submission information (Clause 11(1) of Schedule 15.3)

#### Code reference

*Clause 11(1) of Schedule 15.3*

#### Code related audit information

*The retailer must ensure the:*

- *DUML database is up to date,*
- *methodology for deriving submission information complies with Schedule 15.5.*

#### Audit observation

The process for calculation of consumption was examined and the application of profiles was checked. The database was checked for accuracy.

#### Audit commentary

Meridian reconciles this DUML load using the DST profile.

The on and off times are derived from a data logger read by AMS and are used to create a shape file. Meridian supplies AMS with the capacity information and AMS calculates the kWh figure for each ICP and includes this in the relevant AV080 file. This process was audited during Meridian's reconciliation participant audit and the AMS agent audit. Compliance was confirmed for both parties.

I compared the database provided to the capacity information Meridian supplied to AMS for the month of February 2024 and found that the loads matched with the database. I checked the December 2024 monthly wattage report and found the festive lights haven't been included. Four strings of festive lights were connected from 6/12/2023 to 17/01/2024. ICC intend to provide these details to Meridian in the May 2024 monthly wattage report. This will need to be added to the December 2023 and January 2024 wattage values in the next available revision.

The field audit found that the database was not within the allowable +/-5% accuracy threshold. In absolute terms, total annual consumption is estimated to be 97,500 kWh lower than the DUML database indicates.

I reviewed the last audit's field findings and found 23 of the 38 errors have not been corrected. ICC have provided an update advising that where possible the discrepancies have been corrected and a small number are still being investigated.

The RAMM database contains dates for light installation but the reporting to Meridian does not identify the date lights were removed or the date lights were installed, which means submission is based on a snapshot at the end of the month. This is not considered compliant.

#### Audit outcome

Non-compliant

Non-compliance	Description		
<p>Audit Ref: 2.1 With: Clause 11(1) of Schedule 15.3</p> <p>From: 03-Jul-23 To: 01-Apr-24</p>	<p>Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUMML database indicates as recorded in <b>section 3.1</b>.</p> <p>Festive light volume not submitted for the period electrically connected from 6/12/2024-17/01/2024.</p> <p>23 of 38 discrepancies from the previous audit not corrected.</p> <p>Submission is based on a snapshot and does not consider the dates of changes during the month.</p> <p>Potential impact: High Actual impact: High Audit history: Multiple time previously Controls: Moderate Breach risk rating: 6</p>		
Audit risk rating	Rationale for audit risk rating		
<b>High</b>	<p>Controls are rated as moderate as the change management process is robust but there is room for improvement to correct historical errors.</p> <p>The impact is assessed to be high, based on the kWh difference being higher than 50,000 kWh per annum.</p>		
Actions taken to resolve the issue		Completion date	Remedial action status
Invercargill CC have been advised on the inaccuracies. Invercargill CC have advised that they will correct/update the database by the date specified.		15/05/2024	Identified
Preventative actions taken to ensure no further issues will occur		Completion date	
<p>Meridian will continue to follow up with Invercargill CC to ensure the corrections/updates are completed.</p> <p>We have assessed our processes and tools to account for historic lamp installations and changes to the database at a daily level. There are checks in place comparing month to month data to identify any material changes and confirm details for these. These are accounted for in monthly submission.</p>		<p>15/12/2024</p> <p>Ongoing</p>	

## 2.2. ICP identifier and items of load (Clause 11(2)(a) and (aa) of Schedule 15.3)

### Code reference

*Clause 11(2)(a) and (aa) of Schedule 15.3*

### Code related audit information

*The DUML database must contain:*

- *each ICP identifier for which the retailer is responsible for the DUML,*
- *the items of load associated with the ICP identifier.*

### Audit observation

The database was checked to confirm an ICP was recorded against each item of load.

### Audit commentary

All items of load have an ICP recorded against them.

### Audit outcome

Compliant

## 2.3. Location of each item of load (Clause 11(2)(b) of Schedule 15.3)

### Code reference

*Clause 11(2)(b) of Schedule 15.3*

### Code related audit information

*The DUML database must contain the location of each DUML item.*

### Audit observation

The database was checked to confirm the location is recorded for all items of load.

### Audit commentary

The RAMM database contains a field for the nearest street address and there are GPS coordinates. All items of load have a GPS co-ordinate and are readily locatable.

### Audit outcome

Compliant

## 2.4. Description and capacity of load (Clause 11(2)(c) and (d) of Schedule 15.3)

### Code reference

*Clause 11(2)(c) and (d) of Schedule 15.3*

### Code related audit information

*The DUML database must contain:*

- *a description of load type for each item of load and any assumptions regarding the capacity,*
- *the capacity of each item in watts.*

### Audit observation

The database was checked to confirm that it contained a field for lamp type and wattage capacity and included any ballast or gear wattage and that all items of load were recorded.

### Audit commentary

The extract provided has fields for lamp make, lamp model and lamp notes, which records the total wattage for the lamp including wattage and ballast, and all were populated.

The accuracy of the lamp wattages and ballasts is discussed in **section 3.1**.

### Audit outcome

Compliant

## 2.5. All load recorded in database (Clause 11(2A) of Schedule 15.3)

### Code reference

*Clause 11(2A) of Schedule 15.3*

### Code related audit information

*The retailer must ensure that each item of DUML for which it is responsible is recorded in this database.*

### Audit observation

The field audit was undertaken of 322 lights using the statistical sampling methodology. The population was divided into the following strata:

- Local Authority A-G,
- Local Authority H-P,
- Local Authority Q-Z, and
- NZTA.

### Audit commentary

The field audit findings for the sample of lamps are summarised in the table below. A detailed spreadsheet was provided to ICC and Meridian.

Discrepancy	Quantity	Comments
Lights in the field not in the database	8	Five are historic and three are LEDs.
Lights in the database not in the field	2	
Incorrect wattages	33	11 of the 33 were LED changes.

The field audit found eight additional lights in the field of the 322 items of load sampled. This is recorded as non-compliance below.

The accuracy of the database is discussed in **section 3.1**.

### Audit outcome

Non-compliant



Non-compliance	Description		
Audit Ref: 2.5 With: Clause 11(2A) of Schedule 15.3  From: 03-Jul-23 To: 01-Apr-24	Eight additional lights were found in the field of the 322 items of load sampled.  Potential impact: Low  Actual impact: Low  Audit history: Multiple times previously  Controls: Moderate  Breach risk rating: 2		
Audit risk rating	Rationale for audit risk rating		
<b>Low</b>	Controls are rated as moderate as the change management process is robust but there is room for improvement to correct historical errors.  The impact is assessed to be low due to the impact on submission.		
Actions taken to resolve the issue		Completion date	Remedial action status
Invercargill CC have been advised on the inaccuracies. Invercargill CC have advised that they will correct/update the database by the date specified.		15/05/2024	Identified
Preventative actions taken to ensure no further issues will occur		Completion date	
Meridian will continue to follow up with Invercargill CC to ensure the corrections/updates are completed.		15/12/2024	

## 2.6. Tracking of load changes (Clause 11(3) of Schedule 15.3)

### Code reference

*Clause 11(3) of Schedule 15.3*

### Code related audit information

*The DUML database must track additions and removals in a manner that allows the total load (in kW) to be retrospectively derived for any given day.*

### Audit observation

The process for tracking of changes in the database was examined.

### Audit commentary

The RAMM database functionality achieves compliance with the code.

### Audit outcome

Compliant

## 2.7. Audit trail (Clause 11(4) of Schedule 15.3)

### **Code reference**

*Clause 11(4) of Schedule 15.3*

### **Code related audit information**

*The DUML database must incorporate an audit trail of all additions and changes that identify:*

- *the before and after values for changes,*
- *the date and time of the change or addition,*
- *the person who made the addition or change to the database.*

### **Audit observation**

The database was checked for audit trails.

### **Audit commentary**

RAMM records audit trail information of changes made.

### **Audit outcome**

Compliant

### 3. ACCURACY OF DUML DATABASE

#### 3.1. Database accuracy (Clause 15.2 and 15.37B(b))

##### Code reference

Clause 15.2 and 15.37B(b)

##### Code related audit information

Audit must verify that the information recorded in the retailer's DUML database is complete and accurate.

##### Audit observation

A database extract was provided, and I assessed the accuracy of this by using the DUML Statistical Sampling Guideline. The table below shows the survey plan.

Plan Item	Comments
Area of interest	Invercargill City Council region
Strata	The database contains items of load in the Invercargill City Council area. The processes for the management of ICC items of load are the same, but I decided to place the items of load into four strata, as follows: <ol style="list-style-type: none"> <li>1. Local Authority A-G,</li> <li>2. Local Authority H-P,</li> <li>3. local Authority Q-Z, and</li> <li>4. Waka Kotahi.</li> </ol>
Area units	I created a pivot table of the roads in each area, and I used a random number generator in a spreadsheet to select a total of 35 sub-units.
Total items of load	322 items of load were checked.

Wattages were checked for alignment with the published standardised wattage table produced by the Electricity Authority against the database or in the case of LED lights against the LED light specification.

The change management process to track changes and timeliness of database updates was evaluated.

##### Audit commentary

##### Field Audit Findings

A field audit was conducted of a statistical sample of 322 items of load. The “database auditing tool” was used to analyse the results, which are shown in the table below.

Result	Percentage	Comments
The point estimate of R	95.5	Wattage from survey is lower than the database wattage by 5.4%
R <sub>L</sub>	86.9	With a 95% level of confidence, it can be concluded that the error could be between –13.1 % and +3.7%.
R <sub>H</sub>	103.7	

These results were categorised in accordance with the “Distributed Unmetered Load Statistical Sampling Audit Guideline”, effective from 1 February 2019 and the table below shows that Scenario C (detailed below) applies.

The conclusion from Scenario C is that the variability of the sample results across the strata means that the true wattage (installed in the field) could be between 13.1% lower and 3.7% higher than the wattage recorded in the DUML database. Non-compliance is recorded because the potential error is greater than 5.0%.

In absolute terms the installed capacity is estimated to be 23 kW lower than the database indicates.

There is a 95% level of confidence that the installed capacity is between 67 kW lower and 19 kW higher than the database.

In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates.

There is a 95% level of confidence that the annual consumption is between 286,100 kWh lower and 81,600 kWh p.a. higher than the database indicates.

Scenario	Description
<b>A - Good accuracy, good precision</b>	This scenario applies if: (a) $R_H$ is less than 1.05; and (b) $R_L$ is greater than 0.95  The conclusion from this scenario is that: (a) the best available estimate indicates that the database is accurate within +/- 5 %; and (b) this is the best outcome.
<b>B - Poor accuracy, demonstrated with statistical significance</b>	This scenario applies if: (a) the point estimate of R is less than 0.95 or greater than 1.05 (b) as a result, either $R_L$ is less than 0.95 or $R_H$ is greater than 1.05.  There is evidence to support this finding. In statistical terms, the inaccuracy is statistically significant at the 95% level
<b>C - Poor precision</b>	This scenario applies if: (a) the point estimate of R is between 0.95 and 1.05 (b) $R_L$ is less than 0.95 and/or $R_H$ is greater than 1.05  The conclusion from this scenario is that the best available estimate is not precise enough to conclude that the database is accurate within +/- 5 %

#### Lamp description and capacity accuracy

The database was checked against the published standardised wattage table, and manufacturer's specifications where available.

LED light specifications were provided in the previous audit by ICC to confirm the correct wattage and ballast is recorded in the database.

I confirmed the incorrect ballasts found in the last audit were corrected. Examination of the database found light ID 41965 is a 70W HPS light with no ballast recorded. This has been passed to ICC to correct.

### **Change management process findings**

The processes were reviewed for new lamp connections and the tracking of load changes due to faults and maintenance.

The field contractor is Network Electrical Servicing, and they are responsible for the Network maintenance. Network Electrical Servicing are issued a Service Request for reactive work and complete a regular maintenance programme. Pocket RAMM is used in the field to issue work and record changes in the field into RAMM. ICC complete random audits of fieldwork to check for completeness and accuracy of information, and invoices are checked. Any additional or incorrect information identified is manually updated in RAMM. Most of the discrepancies relate to errors made during the LED upgrade programme of work that finished some years ago. ICC intend to undertake their own field audit programme to correct these historic errors.

New subdivisions require a proposed plan to be provided and an “as built” plan once the development is complete. New streetlights are only electrically connected once they have been vested. When the lights are vested to the council they are added to the database. There is very little new development in progress in Invercargill.

I reviewed the last audit’s field findings and found 23 of the 38 errors have not been corrected. ICC have provided an update advising that where possible the discrepancies have been corrected and a small number are still being investigated.

### **Festive lights**

Festive lighting has been added to the RAMM database and these items are expected to be included in the monthly report to Meridian when electrically connected but upon checking the December 2024 wattage report these were omitted. This is recorded as non-compliance in **sections 2.1** and **3.2**.

### **Private lights**

There are no private lights recorded in the ICC database. All private lights are recorded as standard or shared unmetered load against the relevant ICPs by the network.

### **Audit outcome**

Non-compliant

Non-compliance	Description		
Audit Ref: 3.1 With: Clause 15.2 and 15.37B(b)  From: 03-Jul-23 To: 01-Apr-24	Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates.  Incorrect ballast applied for one lamp.  23 of 38 discrepancies from the previous audit not corrected.  Potential impact: High Actual impact: High Audit history: Multiple times previously  Controls: Moderate Breach risk rating: 6		
Audit risk rating	Rationale for audit risk rating		
<b>High</b>	Controls are rated as moderate as the change management process is robust but there is room for improvement to correct historical errors.  The impact is assessed to be high, based on the kWh difference being higher than 50,000 kWh per annum.		
Actions taken to resolve the issue		Completion date	Remedial action status
Invercargill CC have been advised on the inaccuracies. Invercargill CC have advised that they will correct/update the database by the date specified.		15/05/2024	Identified
Preventative actions taken to ensure no further issues will occur		Completion date	
Meridian will continue to follow up with Invercargill CC to ensure the corrections/updates are completed.		15/12/2024	

### 3.2. Volume information accuracy (Clause 15.2 and 15.37B(c))

#### Code reference

Clause 15.2 and 15.37B(c)

#### Code related audit information

The audit must verify that:

- volume information for the DUML is being calculated accurately,
- profiles for DUML have been correctly applied.

#### Audit observation

The submission was checked for accuracy for the month the database extract was supplied. This included:

- checking the registry to confirm that the ICP has the correct profile and submission flag, and
- checking the database extract combined with the burn hours against the submitted figure to confirm accuracy.

### **Audit commentary**

The on and off times are derived from a data logger read by AMS and are used to create a shape file. Meridian supplies AMS with the capacity information and AMS calculates the kWh figure for each ICP and includes this in the relevant AV080 file. This process was audited during Meridian's reconciliation participant audit and the AMS agent audit. Compliance was confirmed for both parties.

I compared the database provided to the capacity information Meridian supplied to AMS for the month of February 2024 and found that the loads matched with the database. I checked the December 2024 monthly wattage report and found the festive lights haven't been included. Four strings of festive lights were connected from 6/12/2023 to 17/01/2024. ICC intend to provide these details to Meridian in the May 2024 monthly wattage report. This will need to be added to the December 2023 and January 2024 wattage values in the next available revision.

The field audit found that the database was not within the allowable +/-5% accuracy threshold. In absolute terms, total annual consumption is estimated to be 97,500 kWh lower than the DUML database indicates.

I reviewed the last audit's field findings and found 23 of the 38 errors have not been corrected. ICC have provided an update advising that where possible the discrepancies have been corrected and a small number are still being investigated.

The RAMM database contains dates for light installation but the reporting to Meridian does not identify the date lights were removed or the date lights were installed, which means submission is based on a snapshot at the end of the month. This is not considered compliant.

### **Audit outcome**

Non-compliant

Non-compliance	Description		
<p>Audit Ref: 3.2</p> <p>With: Clause 15.2 and 15.37B(c)</p> <p>From: 03-Jul-23</p> <p>To: 01-Apr-24</p>	<p>Database is not confirmed as accurate with a 95% level of confidence. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates as recorded in <b>section 3.1</b>.</p> <p>Festive light volume not submitted for the period electrically connected from 6/12/2024-17/01/2024.</p> <p>23 of 38 discrepancies from the previous audit not corrected.</p> <p>Submission is based on a snapshot and does not consider the dates of changes during the month.</p> <p>Potential impact: High</p> <p>Actual impact: High</p> <p>Audit history: Multiple time previously</p> <p>Controls: Moderate</p> <p>Breach risk rating: 6</p>		
Audit risk rating	Rationale for audit risk rating		
<p><b>High</b></p>	<p>Controls are rated as moderate as the change management process is robust but there is room for improvement to correct historical errors.</p> <p>The impact is assessed to be high, based on the kWh difference being higher than 50,000 kWh per annum.</p>		
Actions taken to resolve the issue		Completion date	Remedial action status
<p>Invercargill CC have been advised on the inaccuracies. Invercargill CC have advised that they will correct/update the database by the date specified.</p>		<p>15/05/2024</p>	<p>Identified</p>
Preventative actions taken to ensure no further issues will occur		Completion date	
<p>Meridian will continue to follow up with Invercargill CC to ensure the corrections/updates are completed.</p> <p>We have assessed our processes and tools to account for historic lamp installations and changes to the database at a daily level. There are checks in place comparing month to month data to identify any material changes and confirm details for these. These are accounted for in monthly submission.</p>		<p>15/12/2024</p> <p>Ongoing</p>	



## CONCLUSION

Meridian reconciles this DUML load using the DST profile.

The on and off times are derived from a data logger read by AMS and are used to create a shape file. Meridian supplies AMS with the capacity information and AMS calculates the kWh figure for each ICP and includes this in the relevant AV080 file. This process was audited during Meridian's reconciliation participant audit and the AMS agent audit. Compliance was confirmed for both parties.

The error in submission identified in the last audit has been corrected and I confirmed that volumes submitted matched the report for February 2024.

The field audit found that the database was not within the allowable +/-5% accuracy threshold. In absolute terms, total annual consumption is estimated to be 97,400 kWh lower than the DUML database indicates. This is a similar result to the last audit. Most of the discrepancies relate to errors made during the LED upgrade programme of work that finished some years ago. ICC intend to undertake their own field audit programme to correct these historic errors.

The audit found four non-compliances and makes no recommendations. The future risk rating of 20 indicates that the next audit be completed in three months. I have considered this in conjunction with Meridian's responses, and the update received from ICC confirming corrections have been made where possible and recommend that the next audit be nine months.

## PARTICIPANT RESPONSE

Response supplied by Council:

Council notes the audit report and plans to undertake a much wider review of the database. The rate of change within the database should reflect a more stable state. Council notes that the consumption is lower than the load and efforts to correct data can return a saving to Council.

Council is committed to correcting the database.

The proposed plan will be to undertake a desktop review of where the issues could have been introduced and set up processes including monthly checks to find and eliminate input errors from field staff.

Additionally, an extensive planned field review will be commenced, over the next 6 months or earlier to field sample and validate the current data to a greater extent. We will look to field validate at least 50% of all installation and review and monitor trends in findings. Field staff will be required to report monthly on progress, findings and issues

A further check with our suppliers to validate the wattage of fittings and align to the standards would be undertaken.

It is understood that SH lights are likely to be withdrawn from AOs and managed centrally and these will be reviewed early in the process.

Previous Audit findings will be loaded into internal audit management software (Promap) which will monitor completion of any findings and check they are completed. Outstanding findings will be completed as a priority.